



Santa Rosa County Life Safety/Fire Prevention Department

Santa Rosa County Public Service Center
6051 Old Bagdad Highway, Room 202
Milton, Florida 32583

John T. "Tim" Tolbert
Building Official
Skip Tompkins
Compliance Division Superintendent

Telephone
850.981.7000
Fax 850.623.1208

Tambre L. Lee
Fire Inspector/ Plans Examiner
Annie Sue Rambo
Fire Inspector

Sequence of Inspections

- Fire Alarm:** (1) Rough-in inspection of device placement and wiring.
(2) Final test and certification of system.
- Fire Sprinkler:** (1) Rough-in inspection of pipe and heads
(2) Pressure test (**INSPECTOR MUST WITNESSED PRESSURE-UP OF SYSTEM AND DURATION OF TEST**)
(3) Final test and certification inspection.
- Fire Suppression
Other than
Sprinkler:** (1) Complete system test. ** Mechanical and electrical components must have passed a rough inspection prior to conduction of test. If gas is a component of the cooking equipment, it is necessary that it has passed inspection and is turned on.**
- Underground
Fire Main:** (1) Thrust blocks and pipe layout.
(2) Pressure test (**INSPECTOR MUST WITNESSED PRESSURE-UP OF PIPE AND DURATION OF TEST**)
- Fire Pump:** (1) Certification test.

*All inspections must be scheduled 24 hours in advance. To schedule an inspection, please call (850) 981-7038 or (850) 981-7042. Your approved set of drawings must be on jobsite at time of inspection. *